

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0065:161 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Faraday Inc, 805 S. Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Model 2705 (20-31 VDC) non-synchronized strobe lights, followed by -E (68cd) or -L (100cd).

Model 2705 (120 VAC) non-synchronized strobe lights, followed by -E (68cd) or -L (100cd).

Model 2705 (20-31 VDC) synchronized strobe lights, followed by suffix -M (68cd) or -Z (100cd). All synchronized strobes must be used with models 5405 or 5406 Sync Module.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for wall and ceiling mount.

MARKING: Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. These devices are not approved for the hearing impaired applications. Models are suitable for outdoor use when used with Model 3014 or 3015 back box

04-05-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager